

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

January 24, 2019

Joe Adelman
Chicago Lighthouse
1850 West Roosevelt Road
Chicago, IL 60608

Workorder: 1901C70

TEL: (312) 666-1331

FAX:

RE: Drinking Water Lead Analysis

Dear Joe Adelman:

Suburban Laboratories, Inc. received 12 sample(s) on 1/21/2019 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
 www.suburbanlabs.com

Client ID: Chicago Lighthouse
Project Name: Drinking Water Lead Analysis

Report Date: January 24, 2019
Workorder: 1901C70

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1901C70-001A	CAFETERIA KITCHEN SINK DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-002A	CAFETERIA KITCHEN SINK FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-003A	CAFETERIA WATER MACHINE DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-004A	CAFETERIA WATER MACHINE FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-005A	SCHOOL CAFETERIA KITCHEN SINK DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-006A	SCHOOL CAFETERIA KITCHEN SINK FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-007A	SCHOOL CAFETERIA WATER MACHINE DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-008A	SCHOOL CAFETERIA WATER MACHINE FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-009A	SHIPPING AREA WATER MACHINE DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-010A	SHIPPING AREA WATER MACHINE FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-011A	2ND FLOOR BREAKROOM SINK DRAW	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019
1901C70-012A	2ND FLOOR BREAKROOM SINK FLUSH	ND	2.00	µg/L	1/17/19 20:00	1/18/2019	1/23/2019